



MANAGEMENT SERVICES DEPARTMENT

Purchasing Division

241 West South Street

Kalamazoo, MI 49007-4796

Phone: 269.337.8020

Fax: 269.337.8500

[www.kalamazoo-city.org](http://www.kalamazoo-city.org)

[purchasing@kalamazoo-city.org](mailto:purchasing@kalamazoo-city.org)

ADDENDUM #3

February 9, 2022

TO: ALL MANDATORY Site Inspection Attendees  
PROJECT NAME: Building 5 Masonry Restoration  
BID REFERENCE #: 91051-010.0  
BID DUE/OPENING DATE: Wednesday, February 16, 2022 at 3:00 p.m. Local Time

The purpose of this addendum is to clarify and/or modify the Drawings and/or Specifications for this project. All work affected is subject to all applicable terms and conditions of the Bidding and Contract Documents.

1. RESPONSE TO QUESTIONS FROM ADDENDUM #2

1.1. Item Q2: to be used on limestone panels. None of these products are proper to be used on limestone, can you please revisit this and clarify more.

A: Follow the supplied specification.

1.2. Item Q8: Caulk has not been tested. Are we supposed to test it prior to start working? And if it is contaminated what is next?

A: Caulk testing is to be provided by the awarded contractor based on industry best practices.

1.3. Item Q9: Intent to replace cracked brick. Item 6 in the key notes refer to replacing cracked brick, are we to assume that every location where note# 2 is mentioned to be brick replacement too? If that is the case, can you please provide a quantity allowance of how many bricks to be replaced so the bidding will be fair.

A: Key note number 2 refers to cracks running in mortar and possible bricks. There are possible locations where key note 2 and 6 overlap. The supplied set of plans are to be used as a guideline for total work scope restoration. All measurements and quantities are the responsibility of bidding contractor.

The Addendum can be viewed and downloaded from the City's website at <https://www.kalamazoo-city.org/bidopportunities>.

**In order for a bid to be responsive, this addendum must be returned, signed and dated, with your bid.** If you have already submitted your bid, acknowledge receipt and acceptance of this addendum by signing in the place provided and returning it to the undersigned and it shall be incorporated in your bid. Please identify your return envelope with the bid reference number and project description.

Sincerely,

**Michelle Emig**

Purchasing Division Manager

c: Chris Nelson, Public Services  
Ryan Stoughton, Public Services  
Prevailing Wage File

FIRM: \_\_\_\_\_

SIGNED: \_\_\_\_\_

NAME: \_\_\_\_\_

(Type or Print)

DATE: \_\_\_\_\_