



MANAGEMENT SERVICES DEPARTMENT

Purchasing Division

241 West South Street

Kalamazoo, MI 49007-4796

Phone: 269.337.8020

Fax: 269.337.8500

www.kalamazoocity.org

purchasing@kalamazoocity.org

ADDENDUM #1

March 7, 2023

TO: ALL Prospective Bidders
PROJECT NAME: Station 25 Booster Pump 2 Rebuild
BID REFERENCE #: 93691-001.0
BID DUE/OPENING DATE: Tuesday, April 4, 2023 at 3:00 p.m. Local Time

The purpose of this addendum is to clarify and/or modify the Bid Opening Date, Bid Items, and Specifications for this project. All work affected is subject to all applicable terms and conditions of the Bidding and Contract Documents.

1. **NOTE:** The **BID OPENING DATE** has been changed to:
Tuesday, April 4, 2023 at 3:00 p.m. Local Time

2. **REPLACE**

2.1. **Replace SECTION II, BID AND AWARD Page 2 with ADDENDUM #1 ATTACHMENT A, REVISED SECTION II, BID AND AWARD (Pages 2 and 2a).** The **REVISED** pages must be used when submitting a bid for this project.

3. **ADDITION**

3.1. **SECTION V, SPECIAL CONDITIONS, 2. GENERAL INFORMATION** (Page 13 of the Invitation for Bids) incorporates the following language in addition to the existing language:

Contractor will be responsible for delivering and installing pump to Station No.25 as outlined in the Scope of Work section.

3.2. **SECTION V, SPECIAL CONDITIONS, 3. SCOPE OF WORK** (Pages 13-14 of the Invitation for Bids) incorporates the following additional sub-section 3.13.:

3.13. ***BID ALTERNATE: New Complete Pump Assembly will include, but not be limited to:***

3.13.1. *Decouple and remove Booster Pump No. 2 from the pump setting and pump skid, rig, lift and place in Contractor-supplied transport vehicle.*

3.13.2. *Dispose of old Booster Pump No. 2 according to all applicable Federal, State, and Local laws and regulations.*

3.13.3. *Deliver new pump to Station No. 25 rig pump and move pump and motor and set in place. Install pump, shim as needed, ensure all pump components are in line with drive line using 3-dimensional laser alignment, and put into service.*

3.13.4. *Provide all operating and manufacturer warranty information to the City at the time of new pump delivery.*

3.13.5. *New pump will adhere to the following specifications:*

Motor Specs

Motor Duty Rating – Continuous Inverter Duty Rated

Motor Windings - Inverter class magnet wire as required under (NEMA) MG1 Part 31 guidelines.

Additional Features – Internally installed circumferential microfiber motor shaft grounding ring

NEMA Nominal Efficiency – 95.8% or greater

Power Factor – 0.87 or greater

Phase – 3

Hertz – 60

Service Factor – 1.15 to 1.25

Insulation Class – F to H, 180 C

Horse Power - 150

Volts – 460

RPM – 1785

NEMA Code – G

Design - B

Enclosure – Outdoor Drip Proof

Installed Altitude – 1000 feet above sea level

Ambient Temperature – 40 C

Pump Frame – 444/445 (as determined to fit supplied pump skid/frame mounting)

Color

Pump, Motor, Frame/Skid

NSF 61 approved Tnemec epoxy Safety Blue

3.3. **SECTION V, SPECIAL CONDITIONS**, incorporates the following additional section 11. **SELECTION CRITERIA**:

11. SELECTION CRITERIA

This purchase will be awarded to the responsive, responsible bidder whose bid will be most advantageous to the City, price and other factors considered. The City reserves the right to accept or reject any or all bids and waive informalities and minor irregularities for bids received. Notification of award will be in writing by the Purchasing Division.

It is the intent of the City to consider both lead time and cost as a decision on the best value / most advantageous to the City. The City values the reliability of Station No.25 and the ability to restore full pumping capacity.

Prospective bidders may bid on either the rebuild only, the new pump only or both the rebuild and the new pump.

*New Pump to Include Coupled New Motor, Complete Pump Frame/Skid Assembly
Pump Specs – Already included within IFB.*

The Addendum can be viewed and downloaded from the City's website at <https://www.kalamazoo.org/bidopportunities>.

In order for a bid to be responsive, this addendum must be returned, signed and dated, with your bid. If you have already submitted your bid, acknowledge receipt and acceptance of this addendum by signing in the place provided and returning it to the undersigned and it shall be incorporated in your bid. Please identify your return envelope with the bid reference number and project description.

Questions regarding the scope of work of this project may be addressed to James Baker, PE, Public Services Director, at (269) 337-8768 or bakerj@kalamazoo.org. Questions relative to general proposal requirements may be addressed to Craig Hull, Buyer at (269) 337-8444.

Sincerely,



Michelle Emig
Purchasing Division Manager

c: James Baker, PE, Public Services Director

FIRM: _____

SIGNED: _____

NAME: _____

DATE: _____

(Type or Print)



**THE CITY OF KALAMAZOO
DEPARTMENT OF PUBLIC SERVICES**

**ADDENDUM #1
ATTACHMENT A**

REVISED

**SECTION II
BID AND AWARD**

Pages 2 and 2a

(The following **REVISED pages must be used
when submitting a bid for this project.)**

**Station 25 Booster Pump 2 Rebuild
Bid Reference #: 93691-001.0**

REVISED
SECTION II
BID AND AWARD

The undersigned having become thoroughly familiar with all of the bid/contract documents incorporated herein, the project site and the location conditions affecting the work, hereby proposes to perform everything required to be performed in strict conformity with the requirements of these documents, and to provide and furnish all the equipment, labor and materials necessary to complete in a professional manner the furnishing and installing of all of the following, meeting or exceeding the specifications as set forth herein for the prices, and within the timeframe, as stated below.

STATION 25 BOOSTER PUMP 2 REBUILD

BASE BID:

Station No.25 Booster Pump No. 2 **Rebuild** Lump Sum Bid: \$ _____

Total time duration from issuance of Notice to Proceed to completed delivered rebuilt pump, installed and operational including all lead times for all materials and components will not exceed _____ Weeks.

BID ALTERNATE

Station No.25 Booster Pump No. 2 **New Complete Pump Assembly** Lump Sum Bid: \$ _____

Total time duration from issuance of Notice to Proceed to shop drawing submittal will not exceed:

_____ Weeks.

Total time duration from issuance of shop drawing approval to completed delivered new pump, installed and operational including all lead times for all materials and components will not exceed:

_____ Weeks.

New Complete Pump Assembly Total Weeks: _____

It is the intent of the City to consider both lead time and cost as a decision on the best value. The City values the reliability of Station No.25 and the ability to restore full pumping capacity.

Prospective bidders may bid on either the rebuild only, the new pump only or both the rebuild and the new pump.

**New Pump to Include Coupled New Motor, Complete Pump Frame/Skid Assembly
Pump Specs – Already included within IFB**

Bidder shall provide all of the information as requested herein with their bid. **Failure to do so and/or failure to provide post-bid requested information may be cause for rejecting the bid as non-responsive.**

Bidder/Contractor has examined and carefully studied the bidding documents and attachments, and acknowledges receipt of the following addenda:

Addendum No: _____

Dated: _____

The City encourages the use of local labor in fulfilling the requirements of this contract.

This contract shall be governed by the laws of the State of Michigan.

By my signature below, I certify that the firm bidding on this contract, when making hiring decisions, does not use a past criminal conviction as a bar to or preclude a person with a criminal conviction from being considered for employment with the bidding firm unless otherwise precluded by federal or state law. I further certify that I have read and agree to be bound by the provisions of the City’s Non-Discrimination Clause found in Appendix A as updated by City Ordinance 1856.

Signed: _____ Name: _____

Title: _____