



**MANAGEMENT SERVICES DEPARTMENT
PURCHASING DIVISION**

241 W. South Street
Kalamazoo, Michigan 49007-4796
Telephone (269) 337-8020
cokpurchasing@kalamazoocity.org

**ADDENDUM #1
July 7, 2026**

TO: ALL Prospective Bidders
PROJECT NAME: Phase 1: Central Pump Station 1 Filter Media Replacement (As Needed) and Misc. Filter Improvements
BID REFERENCE #: 90900-029.0
BID OPENING DATE/TIME: **July 21, 2026 @ 3:30 p.m. Local Time (ET)**
Electronic Bids Will Not Be Accepted.

The purpose of this addendum is to clarify and/or modify the Drawings and/or Specifications for this project. All work affected is subject to all applicable terms and conditions of the Bidding and Contract Documents.

1. NOTE: NEW BID DUE/OPENING DATE/TIME: July 21, 2026 @ 3:30 p.m. Local Time (ET)

QUESTION 1: What is the existing filter media?

ANSWER 1: The existing filter media is manganese greensand.

Bidders shall address questions regarding the specifications to Anna Crandall, P.E., Assistant City Engineer at crandalla@kalamazoocity.org, (This does not relieve the requirements of Page 1, Item 3.) Questions regarding terms, conditions and other related bid requirements may be addressed to Kyle Dunn, Buyer at (269) 337-8720 or dunnk@kalamazoocity.org.

The Addendum can be viewed and downloaded from the City's website at <https://www.kalamazoocity.org/bidopportunities>.

In order for a bid to be responsive, this signed and dated addendum must be returned with your bid. If you have already submitted your bid, acknowledge receipt and acceptance of this addendum by signing in the place provided and returning it to the undersigned and it shall be incorporated in your bid. Please identify your return envelope with the bid reference number and project description.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Michelle Emig'.

Michelle Emig
Purchasing Division Manager

c: Anna Crandall, Public Services

FIRM: _____

SIGNED: _____

NAME: _____

DATE: _____