



MANAGEMENT SERVICES DEPARTMENT

Purchasing Division

241 West South Street

Kalamazoo, MI 49007-4796

Phone: 269.337.8020

Fax: 269.337.8500

[www.kalamazoocity.org](http://www.kalamazoocity.org)

[purchasing@kalamazoocity.org](mailto:purchasing@kalamazoocity.org)

ADDENDUM #2

March 18, 2022

TO: ALL MANDATORY Pre-Bid Meeting Attendees  
PROJECT NAME: Contract 76 B.1-Biological Foul Air Mitigation System-Construction-Rebid  
BID REFERENCE #: 91359-003.0  
BID DUE/OPENING DATE: Tuesday, March 29, 2022 at 3:00 p.m. Local Time

The purpose of this addendum is to clarify the Bid Items, Drawings and/or Specifications for this project. All work affected is subject to all applicable terms and conditions of the Bidding and Contract Documents.

1. RESPONSE TO QUESTIONS

**Q1: Reference Drawing C-5 & P-2: Please clarify what the natural gas requirements are for the new building. The site drawings seem to indicate the contractor is supposed to run a substantial amount of new gas pipe. The plumbing drawings seem to indicate a new service is being run to the building by the utility company including a new meter.**

**A:** Drawing C-5 & P-2 correctly states the size of the Natural Gas piping the Owner is requesting to be Bid for supply and installation under this Contract. The Contractor is to install new gas piping as indicated on the Drawings. The Contractor, under this Contract, is responsible for supply and installation of all natural gas infrastructure. Natural Gas infrastructure shown in the Bid Drawings, and part of this Contract, is downstream of (after) the KWRP's Natural Gas Master Meter. All natural gas distribution infrastructure downstream (after) the KWRP's Natural Gas Master Meter is the ownership and responsibility of the City. The shown natural gas infrastructure shall be supplied and installed per specifications, industry best practices, or Consumers Energy's standards, whichever is more strict.

The Addendum can be viewed and downloaded from the City's website at <https://www.kalamazoocity.org/bidopportunities>.

**In order for a bid to be responsive, this addendum must be returned, signed and dated, with your bid.** If you have already submitted your bid, acknowledge receipt and acceptance of this addendum by signing in the place provided and returning it to the undersigned and it shall be incorporated in your bid. Please identify your return envelope with the bid reference number and project description.

Sincerely,

**Michelle Emig**

*Purchasing Division Manager*

c: Ryan Stoughton, Public Services  
Chris Nelson, Public Services  
James Cornell, Public Services  
Prevailing Wage File

FIRM: \_\_\_\_\_

SIGNED: \_\_\_\_\_

NAME: \_\_\_\_\_

DATE: \_\_\_\_\_

(Type or Print)